DATASHEET - M22-WRK4



Changeover switch, RMQ-Titan, With thumb-grip, maintained, 4 positions, Bezel: titanium $\,$



Part no. M22-WRK4

279431

EL Number

4355456

(N	or	w	ay
----	----	---	----

General specifications	
Product name	Eaton Moeller® series M22 Changeover switch
Part no.	M22-WRK4
EAN	4015082794316
Product Length/Depth	45 millimetre
Product height	30 millimetre
Product width	30 millimetre
Product weight	0.016 kilogram
Compliances	CE Marked
Certifications	CSA Std. C22.2 No. 14-05 IEC 60947-5 CSA Std. C22.2 No. 94-91 EN 60947-5 UL 508 VDE CSA Class No.: 3211-03 CSA VDE 0660 UL Category Control No.: NKCR IEC/EN 60947-5 CSA-C22.2 No. 94-91 UL File No.: E29184 CE UL CSA-C22.2 No. 14-05 CSA File No.: 012528 IEC/EN 60947
Product Tradename	M22
Product Type	Changeover switch
Product Sub Type	None
Catalog Notes	Labels → accessories
	Not suitable for coding adapters
Features & Functions	
Bezel color	Titanium
Bezel material	Plastic
Color	Black
Design	With thumb-grip
Fitted with:	Front ring
General information	
Accessories	Thumb-grip
Degree of protection	NEMA 4X, 13
Degree of protection (front side)	IP66
Lifespan, mechanical	100,000 Operations
Opening diameter	22.5 mm
Operating frequency	2000 Operations/h
Operating torque	0.3 N·m
Product category	RMQ-Titan
Size	Front diameter: 29.7 mm
Туре	Selector switch actuator
Used with	M22-A4 fixing adapter
Ambient conditions, mechanical	
Mounting position	As required
Shock resistance	Mechanical, According to IEC/EN 60068-2-27 30 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms

Ambient operating temperaturs - min Ambient operating temperaturs - max Ambient organize premoteratur - min Ambient strange temperaturs - min Ambient strange temperaturs - max Climate profiling Damp heat, cyclic, is IEE 80088-2-30 Damp heat, contract, to IEE 80088-2-30 Damp heat, contract,	Climatic anniversated conditions	
Ambient opporating temperature - minx Ambient opporature - minx Ambient strange temperature - minx Ambient strange temperature - minx Climatic propring Communication Commence on to SmartWire-DT Communication Commence on to SmartWire-DT Actuator Actuator Actuator Actuator recipies Actuator properature - minx Actuator function Actuator properature - minx Actuator function Actuator recipies Actuator properature - minx Actuator function Actuator recipies Actuator properature - minx Actuator function Actuator properature - minx Actuator function Actuator properature - minx Actuator function Actuator function Actuator function Actuator properature - minx Actuator function Act	Climatic environmental conditions	
Ambient storage temperature - min Communication Communication Commerciant to SmartWire-DT With SWO-PMM connections Tes Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Actuator Tagge Tagge Number of switch pastions 2 Contacts Force for positive spening - min Design verification Equipment head disapation, current-dependent Priof Read disapation, person, pe		
Ambient storage transpersion - max Climate proofing Damp heat, cyclic, to EC 60008 2-00 Damp heat, cyclic, to EC 60008 2-00 Damp heat, constant, to EC 60008 2-70 Wish SWD-RMQ connections Vais SWD-RMQ connections Vais SWD-RMQ connections Vais SWD-RMQ connections Vais SWD-RMQ connections Actuator color Actuator function Actuator type Actuator function Actuator type Triggie Actuator type Number of aswich positions 2 Connection Force for positive opening - min Design verification Esquipment heat dissipation, current-dependent Pvid Near dissipation per pole, current dependent Pvid Near dissipation per pole dependent Pvid Near		
Climatic proofing Communication Connection to SinstriVine-DT Actuator Actuator Actuator Black Actuator Actuator Indication Act	Ambient storage temperature - min	
Communication Communication Communication Communication Communication Communication Communication Communication Communication Actuator function Actuator function Actuator function Actuator type Actuator type Actuator type Number of switch positions Contacts Force for positive opening - min Design verification Equipment head dissipation, current dependent Pvid Equipment head dissipation type (and the dissipation Ini) Static head dissipation, non-current dependent Pvid Equipment head dissipation (and the dissipation Ini) Static head dissipation, non-current dependent Pvid Initiation of thermal stability of enclosures Initiation (and the minimal stability of enclosures Initiation (and the minim		80 °C
Connection to SmartVirre-DT Actuator Actuator color Actuator function Actuator function function Actuator function Actuat	Climatic proofing	
Actuator color Actuator function Actuator type Actuator type Toggle Nimber of switch positions Contacts Ferce for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid float dissipation capacity Pvides Float dissipation capacity Pvides OW Ratad operational current for specified heat dissipation (In) Ratad operational current for specified heat dissipation	Communication	
Actuator rolor Actuator function Biogin verification Cequipment heat dissipation, current-dependent Pvid Actuator dependent Pvid Bed dissipation capacity Pdiss Actuator dependent Pvid Bed dissipation per pole, current-dependent Pvid Actuator dissipation per pole, current-dependent Pvid Actuator dissipation, non-current-dependent Pvid Actuator dissipation function Actuator dissipation Actuato	Connection to SmartWire-DT	
Actuator type Oracles Force for positive opening - min Design verification Equipment had dissipation, current-dependent Pvid Heat dissipation per polit, current-dependent Pvid Heat dissipation, non-current-dependent Pvid Heat dissipation, uncorrected Pvid Heat dissipati	Actuator	
Actuator type Number of switch positions Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Prids Heat dissipation per pole, current-dependent Pvid Heat dissipation concurrent-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation concurrent-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid Heat dissipation of resistance Heat dissipation of resistance of insulating materials to normal heat Heat dissipation of non-current-dependent Pvid Heat dissipation of thermal stability of enclosures Heat dissipation of thermal stability of enclosures Heat dissipation of resistance of insulating materials to normal heat Heat dissipation of resistance or insulating materials to normal heat Heat dissipation of resistance or ultra-violet (IV) radiation Heat dissipation of resistance or insulating entire by internal elect. effects Heat dissipation of resistance or insulating entire by internal elect. effects Heat dissipation of resistance or insulating entire by internal elect. effects Heat dissipation of resistance or insulating entire by internal elect. effects Heat dissipation of resistance or insulating entire by internal elect. effects Heat dissipation of entire switchgear needs to be evaluated. Heat the internal entire which gear needs to be evaluated. Heat the product standard's requirements. Heat the product stand	Actuator color	Black
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid Heat dissipation per pole, current-dependent Pvid A Rated operational current for specified heat dissipation (IIn) Static heat dissipation, one-current-dependent Pvid Rated operational current for specified heat dissipation (IIn) 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of the runal stability of enclosures 10.2.3.2 Resistance to ultra-violet (IVI) radiation 10.2.3 Resistance to ultra-violet (IVI) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Incriptions 10.2.6 Mechanical impact 10.2.7 Incriptions 10.2.8 Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.2.7 Incriptions 10.2.8 Meets the product standard's requirements. 10.3 Degree of protection of sexitance to ultra-violet (IVI) radiation 10.2.1 Incriptions 10.2.2 Incriptions 10.2.3 Incriptions 10.2.4 Resistance to ultra-violet (IVI) radiation 10.2.7 Incriptions 10.8 Incorporation of assemblies 10.9 Ones not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Incorporation of switching devices and components 10.5 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Incorporation of switching devices and components 10.9 Incorporation of switching d	Actuator function	
Contacts Force for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation, current-dependent Pvid OW Reted operational current for specified heat dissipation (In) State heat dissipation per pole, current-dependent Pvid OW Reted operational current for specified heat dissipation (In) State heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (IUV) radiation Please enquire 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Dearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 Prover-frequency electric strength Is the panel builder's responsibility. 10.9.1 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Actuator type	Toggle
Porce for positive opening - min Design verification Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss OW Heat dissipation capacity Pdiss OW Rated operational current for specified heat dissipation (In) Static heat dissipation, pro-current-dependent Pvid OW Rated operational current for specified heat dissipation (In) OA Static heat dissipation, non-current-dependent Pvs OW 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.1 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Cloarances and creopage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Insulps withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Number of switch positions	2
Design verification Equipment heat dissipation, current-dependent Pvid 0W Heat dissipation capacity Pdiss 0W Rated operational current for specified heat dissipation (In) 0A State heat dissipation, non-current-dependent Pvid 0W Rated operational current for specified heat dissipation (In) 0A State heat dissipation, non-current-dependent Pvs 0W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.24.8 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strongth Sometime of insulating material Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material I	Contacts	
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs OW 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.4 Resistance to ultra-violet (UV) radiation 10.25. Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.9 Power-frequency electric strength 10.9.9 Power-frequency electric strength 10.9.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction The device meets the requirements, provided the information in the instruction	Force for positive opening - min	0 N
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.8 Resistance to ultra-violet (UV) radiation 10.25.1 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact 10.26 Mechanical impact 10.30 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connection	Design verification	
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.24.8 Resistance to ultra-violet (UV) radiation 10.25.1 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact 10.26 Mechanical impact 10.30 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 10.9 Internal electrical circuits and connection	Equipment heat dissipation, current-dependent Pvid	0 W
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Resist of insul, mat. to abnormal heat/fire by internal elect. effects 10.2.3 Resist of insul, mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Learances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Protection agnity is necessary and components observed. 10.15 Protection agnity is necessary and components of external conductors 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Mechanical function 10.18 Connections for external conductors 10.19 Temperature rise 10.10 Temperature rise 10.11 Celevic meets the requirements, provided the information in the instruction		
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Resist of insul, mat. to abnormal heat/fire by internal elect. effects 10.2.3 Resist of insul, mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Testing of enclosures made of insulating material 10.1 Testing of enclosures made of insulating material 10.2 Electromagnetic compatibility 10.3 Mechanical function The device meets the requirements, provided the information in the instruction		0 W
Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. affects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Protection of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Electromagnetic compatibility 10.15 Protection against electric shock 10.16 Incorporation of switching devices and components 10.17 Internal electrical circuits and connections 10.18 the panel builder's responsibility. 10.19 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Mechanical function 10.18 Mechanical function		0 A
10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the produ		
10.2.3 2 Verification of resistance of insulating materials to normal heat 10.2.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear meeds to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction		Meets the product standard's requirements.
10.2.3 2 Verification of resistance of insulating materials to normal heat 10.2.3 Resist of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear meeds to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation Please enquire Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Soes not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Soes not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Soes not apply, since the entire switchgear needs to be evaluated. Soes not apply, since the entire switchgear needs to be evaluated. Soes not apply, since the entire switchgear needs to be evaluated. Soes not apply, since the entire switchgear needs to be evaluated. Soes not apply, since the entire switchgear needs to be evaluated. Soes not apply, since the entire switchgear needs	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.4 Resistance to ultra-violet (UV) radiation	Please enquire
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 1s the panel builder's responsibility. Not applicable. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Not applicable. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 1s the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise Not applicable. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
10.10 Temperature rise Not applicable. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		Is the panel builder's responsibility.
10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		Is the panel builder's responsibility. The specifications for the switchgear must be
10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be
	10.13 Mechanical function	The device meets the requirements, provided the information in the instruction

Technical data ETIM 9.0

Low-voltage industrial components (EG000017) / Front element for selector switch (EC000222)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for selector switches (ecl@ss13-27-37-12-13 [AKF031019])

[AKF031019])	
Number of switch positions	2
Type of control element	Toggle
Suitable for illumination	No
Colour control element	Black

Colour indicator light cap		Other
Construction type lens		Round
Hole diameter	mm	22.5
Width opening	mm	0
Height opening	mm	0
Switching function latching		Yes
Spring-return		No
With front ring		Yes
Material front ring		Plastic
Colour front ring		Titanium
Degree of protection (IP), front side		IP66
Degree of protection (NEMA)		4X, 13